



San Juan De Dios Educational Foundation, Inc. (Hospital)  
ISO 9001 (Quality); ISO 14001 (Environment);  
OHSAS 18001 (Occupational Health & Safety)  
CERTIFIED

**MICROBIAL DENSITY OF AIR**

AREA	NUMBER OF COLONIES		GRAM STAIN	
	BAP	NA	Gram Positive	Gram Negative
Pre Air free Exposure SJDEFI				
SJU Ward				
Area 1	4 cols.	4 cols.	8 cols.	N/A
Area 2	4 cols.	2 cols.	6 cols.	N/A
Area 3	3 cols.	2 cols.	5 cols.	N/A
Area 4	6 cols.	6 cols.	12 cols.	N/A
Area 5	4 cols.	8 cols.	12 cols.	N/A
Area 6	3 cols.	5 cols.	8 cols.	N/A
Area 7	6 cols.	8 cols.	14 cols.	N/A
Area 8	4 cols.	4 cols.	8 cols.	N/A
Area 9	6 cols.	6 cols.	12 cols.	N/A
Area 10	4 cols.	6 cols.	10 cols.	N/A

ASD-CLU-026-03

REMARKS: 15 Minutes of exposure

Date Performed: December 16, 2008

Performed by: [Signature]  
E. Reyes, R.M.T.  
Medical Technologist

[Signature]  
Jaime Zamora, M.D.  
Pathologist

Date: December 18, 2008



**San Juan De Dios Educational Foundation, Inc. (Hospital)**  
 ISO 9001 (Quality), ISO 14001 (Environment),  
 OHSAS 18001 (Occupational Health & Safety)  
 CERTIFIED

**MICROBIAL DENSITY OF AIR**

AREA	NUMBER OF COLONIES		GRAM STAIN	
	NA	BAP	Gram Positive	Gram Negative
<b>SJDEFI</b>				
<b>42<sup>nd</sup> Day Post exposure of Air free</b>				
<b>SJU</b>				
Area 1	4 cols.	4 cols.	8 cols.	N/A
Area 2	2 cols.	1 cols.	3 cols.	N/A
Area 3	2 cols.	2 cols.	4 cols.	N/A
Area 4	No Growth	No Growth	N/A	N/A
Area 5	2 cols.	2 cols.	4 cols.	N/A
Area 6	3 cols.	2 cols.	5 cols.	N/A
Area 7	No Growth	No Growth	N/A	N/A
Area 8	No Growth	No Growth	N/A	N/A
Area 9	No Growth	No Growth	N/A	N/A
Area 10	No Growth	No Growth	N/A	N/A

ASD-CLU-026-03

REMARKS: 15 Minutes of exposure

Date Performed: January 28, 2009

Performed by:   
Eugene Reyes RMT  
**Medical Technologist**

**Jaime Zamaco M.D.**  
**Pathologist**

Date: January 31, 2009



San Juan De Dios Educational Foundation, Inc. (Hospital)  
ISO 9001 (Quality), ISO 14001 (Environment),  
OHSAS 18001 (Occupational Health & Safety)  
CERTIFIED

**MICROBIAL DENSITY OF AIR**


AREA	NUMBER OF COLONIES		GRAM STAIN	
	NA	BAP	Gram Positive	Gram Negative
SJDEFI				
35 <sup>th</sup> Day Post exposure of Air free SJU				
Area 1	6 cols.	4 cols.	10 cols.	N/A
Area 2	2 cols.	1 cols.	3 cols.	N/A
Area 3	4 cols.	3 cols.	7 cols.	N/A
Area 4	No Growth	No Growth	N/A	N/A
Area 5	2 cols.	2 cols.	4 cols.	N/A
Area 6	5 cols.	4 cols.	9 cols.	N/A
Area 7	No Growth	No Growth	N/A	N/A
Area 8	No Growth	No Growth	N/A	N/A
Area 9	No Growth	No Growth	N/A	N/A
Area 10	No Growth	No Growth	N/A	N/A

ASD-CLU-026-03

REMARKS: 15 Minutes of exposure

Date Performed: January 21, 2009

Performed by:   
Eugene Reyes RMT  
Medical Technologist

  
Jaime Zamuco M.D.  
Pathologist

Date: January 23, 2009



San Juan De Dios Educational Foundation, Inc. (Hospital)  
 ISO 9001 (Quality); ISO 14001 (Environment);  
 OHSAS 18001 (Occupational Health & Safety)  
 CERTIFIED

**MICROBIAL DENSITY OF AIR**

AREA	NUMBER OF COLONIES		GRAM STAIN	
	NA	BAP	Gram Positive	Gram Negative
<b>SJDEFI</b>				
<b>28<sup>th</sup> Day Post exposure of Air free SJU</b>				
Area 1	2 cols.	4 cols.	6 cols.	N/A
Area 2	2 cols.	2 cols.	4 cols.	N/A
Area 3	No Growth	No Growth	N/A	N/A
Area 4	2 cols.	2 cols.	4 cols.	N/A
Area 5	No Growth	No growth	N/A	N/A
Area 6	6 cols.	2 cols.	8 cols.	N/A
Area 7	No Growth	No Growth	N/A	N/A
Area 8	No Growth	No Growth	N/A	N/A
Area 9	No Growth	No Growth	N/A	N/A
Area 10	No Growth	No Growth	N/A	N/A

ASD-CLU-026-03

REMARKS: 15 Minutes of exposure

Date Performed: January 14, 2009

Performed by: Eugene Reyes BMT  
 Medical Technologist

Jaime Zamuco M.D.  
 Pathologist

Date: January 16, 2009





San Juan De Dios Educational Foundation, Inc. (Hospital)  
ISO 9001 (Quality); ISO 14001 (Environment);  
OHSAS 18001 (Occupational Health & Safety)  
CERTIFIED

**MICROBIAL DENSITY OF AIR**

AREA	NUMBER OF COLONIES		GRAM STAIN	
	NA	BAP	Gram Positive	Gram Negative
SJDEFI				
21 <sup>st</sup> Day Post exposure of Air free SJU				
Area 1	No Growth	No Growth	N/A	N/A
Area 2	4 cols.	3 cols.	7 cols.	N/A
Area 3	No Growth	No Growth	N/A	N/A
Area 4	4 cols.	4 cols.	8 cols.	N/A
Area 5	3 cols.	3cols.	6 cols.	N/A
Area 6	No Growth	No Growth	N/A	N/A
Area 7	2 cols.	4 cols.	6 cols.	N/A
Area 8	2 cols.	3cols	5 cols	N/A
Area 9	No growth	No Growth	N/A	N/A
Area 10	3 cols.	3cols.	6 cols.	N/A

ASD-CLU-026-03

REMARKS: 15 Minutes of exposure

Date Performed: January 7, 2009

Performed by: Eugene Reyes RMT  
Medical Technologist

Jaime Zamaco M.D.  
Pathologist

Date: January 9, 2009



**San Juan De Dios Educational Foundation, Inc. (Hospital)**  
 ISO 9001 (Quality), ISO 14001 (Environment),  
 OHSAS 18001 (Occupational Health & Safety)  
**CERTIFIED**


**MICROBIAL DENSITY OF AIR**


AREA	NUMBER OF COLONIES		GRAM STAIN	
	NA	BAP	Gram Positive	Gram Negative
SJDEFI				
14 <sup>th</sup> Day Post exposure of Air free				
SJU				
Area 1	2 cols.	4 cols.	6 cols.	N/A
Area 2	No Growth	No Growth	N/A	N/A
Area 3	No Growth	No Growth	N/A	N/A
Area 4	3 cols.	No Growth	3 cols.	N/A
Area 5	No Growth	No Growth	N/A	N/A
Area 6	No Growth	No Growth	N/A	N/A
Area 7	2 cols.	2 cols.	4 cols.	N/A
Area 8	2 cols.	7 cols.	9 cols.	N/A
Area 9	No Growth	3 cols.	3 cols.	N/A
Area 10	3 cols.	No Growth	3 cols.	N/A

ASD-CLU-026-03

REMARKS: 15 Minutes of exposure

Date Performed: December 31, 2008

Performed by:   
Eugene Reyes RMT  
 Medical Technologist

  
Jaime Zamudio M.D.  
 Pathologist

Date: January 2, 2009



San Juan De Dios Educational Foundation, Inc. (Hospital)  
 ISO 9001 (Quality); ISO 14001 (Environment);  
 OHSAS 18001 (Occupational Health & Safety)  
 CERTIFIED

MICROBIAL DENSITY OF AIR

AREA	NUMBER OF COLONIES		GRAM STAIN	
	NA	BAP	Gram Positive	Gram Negative
7th Day Post Exposure				
Air Free				
SJDEFI				
SJU Ward				
Area 1	6 cols.	4 cols.	10 cols.	N/A
Area 2	5 cols.	5 cols.	10 cols.	N/A
Area 3	4 cols.	6 cols.	10 cols.	N/A
Area 4	4 cols.	5 cols.	9 cols.	N/A
Area 5	1 col.	2 cols.	3 cols.	N/A
Area 6	No Growth	No Growth	N/A	N/A
Area 7	No Growth	3 cols.	3 cols.	N/A
Area 8	No Growth	No Growth	N/A	N/A
Area 9	2 cols.	No Growth	2 cols.	N/A
Area 10	2 cols.	2 cols.	4 cols.	N/A

ASD-CLU-026-03

REMARKS: 15 Minutes of exposure

Date Performed: December 24, 2008

Performed by: Eugene Reyes RMT  
 Medical Technologist

Jaime Zamora M.D.  
 Pathologist

Date: December 26, 2008



San Juan De Dios Educational Foundation, Inc. (Hospital)  
ISO 9001 (Quality), ISO 14001 (Environment),  
OHSAS 18001 (Occupational Health & Safety)  
CERTIFIED

**MICROBIAL DENSITY OF AIR**

AREA	NUMBER OF COLONIES		GRAM STAIN	
	NA	BAP	Gram Positive	Gram Negative
<b>1 Day Post Exposure</b>				
<b>Air Free</b>				
<b>SJDEFI</b>				
<b>SJU Ward</b>				
Area 1	No Growth	No Growth	N/A	N/A
Area 2	No Growth	No Growth	N/A	N/A
Area 3	5 cols.	4 cols.	9 cols.	N/A
Area 4	3 cols.	3 cols.	6 cols.	N/A
Area 5	No Growth	No Growth	N/A	N/A
Area 6	3 cols.	3 cols.	6 cols.	N/A
Area 7	3 cols.	No Growth	3 cols.	N/A
Area 8	3 cols.	No Growth	3 cols.	N/A
Area 9	No Growth	No Growth	No Growth	N/A
Area 10	4 cols	2 cols	6 cols	N/A

ASD-CLU-026-03

REMARKS: 15 Minutes of exposure

Date Performed: December 17, 2008

Performed by: Eugene Reyes RMT  
Medical Technologist

Jaime Zamora M.D.  
Pathologist

Date: December 19, 2008